



CITY OF PALM BEACH GARDENS

PURCHASING DEPARTMENT

SOLICITATION ADDENDUM

Addendum No. 5

DATE: June 9, 2021

TO: All Potential Proposers

SOLICITATION NO.: RFP2021-064CS

TITLE: Design and Construction of Aquatics Center Building at Burns Road Community Center

DUE DATE: Friday, June 25, 2021 @ 3:00PM

This Addendum is and does become a part of the above-mentioned Solicitation.

The following questions were received from a potential proposer, and the responses are provided as shown.

Question 1: Can the city provide the construction documents of the Burns Road Community Center? Preferably PDFs of the 100% construction documents. Please advise.

Response: *The Burns Road Community Center original 1981 Construction Plans, 2005 Expansion Record Drawings, and the Lakeside Center Paving, Grading, Drainage, Water & Sewer Plans are attached.*

Question 2: Page 63 of the Design / Build Criteria lists the aluminum entry doors to Room 100 as:
a. Single door 4'0" x 8'0".
b. Double door 8'0" x 8'0".
c. Please note that aluminum door leaves in excess of 3'6" tend to be both very heavy and unstable. In addition, oversized doors are expensive.
d. Commercial aluminum fully glazed doors are optimally 3'0" x 7'0".
e. Does the City really want door leaves of 4'0" wide and 8'0" tall."
Please advise.

Response: *The Exterior Door section for Room 100 is amended to read:*

Double Doors 6'-0" W x 7'-0" H Aluminum/Glass Exterior Storefront Doors with Kynar Finish for front entrance, and three (3) Single Doors 3'-0" W x 7'-0" H Aluminum/Glass Exterior Storefront Door with Kynar Finish leading to pool areas.

All other terms, covenants and conditions of the subject solicitation and any addenda issued thereto shall apply, except to the extent herein amended.

Km! Ra

CPPO, CPPB, CPSM, C.P.M., CAP-OM, CPCP, FCCM, PMP
Purchasing and Contracts Director

Attachments