



CITY OF PALM BEACH GARDENS

PURCHASING DEPARTMENT

SOLICITATION ADDENDUM

Addendum No. 16

DATE: July 29, 2021

TO: All Potential Bidders

SOLICITATION NO.: ITB2021-137GF

TITLE: Construction of Par 3 Golf Clubhouse at Sandhill Crane Golf Club

DUE DATE: Friday, July 30, 2021, at 3:00PM

This Addendum is and does become a part of the above-mentioned Solicitation.

The following question was received from a potential bidder and the response is provided as shown.

Question: Please confirm the roof sheathing required for the standing seam metal roof system. Should the sheathing be 5/8" or 3/4" Plywood, and will the plywood need to be FRT?

Response: *3/4" Plywood Sheathing. FRT is NOT needed.*

All other terms, covenants and conditions of the subject solicitation and any addenda issued thereto shall apply, except to the extent herein amended.

Km! Ra

CPPO, CPPB, CPSM, C.P.M., CAP-OM, CPCP, FCCM, PMP
Purchasing and Contracts Director