



CITY OF PALM BEACH GARDENS

PURCHASING DEPARTMENT

SOLICITATION ADDENDUM

Addendum No. 11

DATE: May 24, 2023

TO: All Potential Bidders

SOLICITATION NO.: ITB2023-159CS

TITLE: Burns Road Community Center Modernization & Expansion Project
– Construction Services

DUE DATE: Friday, May 26, 2023 @ 3:30PM

This Addendum is and does become a part of the above-mentioned solicitation.

The following question was received from potential a bidder and the response is provided as shown below.

Question: Drawing A1-406 indicates an elevator hoist way width of 6'-11". Per elevator companies an elevator with front and rear opening doors will not fit this depth. Thyssenkrupp elevators (Basis of Design) need a depth of 7'-10 3/4". Please address.

Response: *Please find attached revised shaft dimensions.*

Attachments

A1-102	Revise elevator shaft size
A1-105	Revise elevator shaft size
A1-406	Revise elevator shaft size
S1-201	Revise elevator shaft size
S1-202	Revise elevator shaft size
S1-204	Revise elevator shaft size
S1-206	Revise elevator shaft size
S1-301	Revise elevator pit detail
S1-406	Revise elevator footing
FA1-101	Add remote annunciator microphone.
FA2-101	Add remote annunciator microphone.

All other terms, covenants and conditions of the subject solicitation and any addenda issued thereto shall apply, except to the extent herein amended.

Km! Ra

CPPO, CPPB, CPSM, C.P.M., CAP-OM, CPCP, FCCM, PMP
Purchasing and Contracts Director